

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. GH-26-665

Dated: 30/4/26

It is certified that an inspection team headed by Lakhvir Singh Health Inspector(Name of Officers with designation) from O/o C.S. RoPar(Name of Department/ Office) Inspected the Holy Child Smart School Vill. Patti Nangal RoPar(Name & Address of the school) on 29/4/26 (date of inspection), checked the water test report

submitted by the school and found that the school has potable drinking water for students and staff of the

institution and is having provision for running water in the toilets and maintaining hygienic sanitation

condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One yearSignature with Seal: [Signature]Name District Health OfficerDesignation : O/o S. RupnagarAssistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department

To

Holy child Smart School
Vill Patti Nangal RoPar

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

It is certified that an inspection team headed by

Dated:

(Name of Officers with designation) from

Lachhu Singh Health Officer

PHED

inspected the Holy Child Smart School Village Patti (Nangal), Post office Manakpur, Tehsil Nangal,

Distt. Rupnagar-140125 on 29/4/26 (date of inspection) and on the basis of Water Test

Report (Attached) bearing no. U. 2026/108 dated 29/4/26 of

(PHED Lab) certified

that the Holy Child

Smart School Village Patti (Nangal), Post office Manakpur, Tehsil Nangal, Distt. Rupnagar-140125 has

safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One year

District Health Officer

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

O/O S. Rupnagar

To

Principal

Holy Child Smart School

Village Patti (Nangal)

Distt. Rupnagar

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

ਸਟੇਟ ਪਬਲਿਕ ਹੈਲਥ ਲਬਾਰਟਰੀ ਪੰਜਾਬ, ਖਰੜ।
State Public Health Laboratory Punjab, Kharar
(Email Id- sphlreports@gmail.com)

ਸੇਵਾ ਵਿਖੇ,

ਸਿਵਲ ਸਰਜਨ, ਰੂਪਨਗਰ

ਵਿਸਾ - ਪਾਣੀ ਦੇ ਸੈਂਪਲਾਂ ਦੀ ਬੈਕਟੀਰੀਅਲ ਅਤੇ ਕੈਮੀਕਲ ਟੈਸਟਾਂ ਦੇ ਅਧਾਰ ਤੇ ਵਿਸਲੇਸਟ ਰਿਪੋਰਟ।

ਆਪ ਵਲੋਂ ਮਿਤੀ 29-04-2026 ਨੂੰ ਭੇਜੇ ਗਏ ਪਾਣੀ ਦੇ ਸੈਂਪਲਾਂ ਦੀ ਵਿਸਲੇਸਟ ਰਿਪੋਰਟ ਇਸ ਲਬਾਰਟਰੀ ਵਿਚ ਕੀਤੇ ਗਏ ਟੈਸਟਾਂ (with respect to BIS guidelines ISO 10500: Drinking water specifications-2012) ਦੇ ਅਧਾਰ ਤੇ ਹੇਠ ਅਨੁਸਾਰ ਹੈ।

ਲੜੀ ਨੰ	ਲੇਬ ਨੰ	ਸੈਂਪਲਾਂ ਦਾ ਵੇਰਵਾ Civil Surgeon, RoopNagar	Urban/ Rural	ਪੀਣ ਯੋਗ/ ਅਯੋਗ	ਅਯੋਗ ਹੋਣ ਦੇ ਕਾਰਣ ਜਾਂ ਹੋਰ ਟਿਪਣੀ
1	815	Semen Station Animal Husbandry Ropar (Tanky) Ropar (Tap Water)	Urban	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0
2	816	Semen Station Animal Husbandry Ropar (Distilled Water) Ropar (R.O)	Urban	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0
3	817	Semen Station Animal Husbandry, Ropar (Submersible Pump)	Urban	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0
4	818	Red Cross Society Ropar (Submersible Pump)	Urban	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0
5	819	Bikramjit Maan, #2921/26 K Gurbax Colony Ropar (Submersible Pump)	Urban	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0
6	820	Mohit Jain, # 2935 CA Gali No.1 Malhotra Colony Ropar (Submersible Pump)	Urban	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0
7	821	Akal Academy-Kamalpur Ropar (R.O)	Urban	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0
8	822	Punjab International Public School Pipalmajra, Ropar (R.O)	Urban	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0
9	823	Holy Child Smart School Patti Nangal Ropar (R.O)	Urban	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0

ਇਹ ਲਬਾਰਟਰੀ ਤਰਤੀਬ ਨਾਲ ਨਾ ਭਰੇ ਸੈਂਪਲ ਦੀ ਆਈ ਗਲਤ ਰਿਪੋਰਟ ਲਈ ਜ਼ਿੰਮੇਵਾਰ ਨਹੀਂ ਹੈ।

ਉਪਰੋਕਤ ਰਿਪੋਰਟ ਹੇਠ ਲਿਖੇ ਕੈਮੀਕਲ ਟੈਸਟਾਂ ਅਤੇ ਬੈਕਟੀਰੀਅਲ ਟੈਸਟਾਂ ਦੀ Acceptable Limit ਦੇ ਅਨੁਸਾਰ ਦਿੱਤੀ ਗਈ ਹੈ।

BIS guidelines Drinking water specifications - (IS 10500:1991/2003/2012)	REQUIREMENT (Acceptable Limit)	Permissible Limit in Absence of Alternate Source
TDS	500	2000
PH	6.5-8.5	No relaxation
Calcium	75	200
Chloride	250	1000
Fluoride	1.0	1.5
Total hardness	200	600
Free residual chlorine	0.2	1.0
Total Coliform Bacteria/100 ml	The Requirement is Coliform Bacteria Should not be Detectable in 100ml Sample.	

4/5/26
ਬੈਕਟੀਰੀਆਲੋਜਿਸਟ
ਇਹ: ਸਟੇਟ ਪਬਲਿਕ ਹੈਲਥ ਲਬਾਰਟਰੀ ਪੰਜਾਬ ਖਰੜ।