

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Lakhvir Singh Health Inspector

(Name of Officers with designation) from O/o C.S. Ropal PHED

inspected the Holy Child Smart School Village Patti (Nangal), Distt. Rupnagar

(Name & Address of the school) on 25/4/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 25/2025/75 dated 30/4/25

of (PHED Lab) certified that

the Holy Child Smart School Village Patti (Nangal), Distt. Rupnagar (Name of school) has safe

drinking water facilities for the students and members of staff of the institution. School is also

maintains the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One year

Signature with Seal: Singh
Name :
Designation :
Name & Address of the Office / Department :

To

Principal

Holy Child Smart School

Village Patti (Nangal)

Distt. Rupnagar

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated: 2/5/25

No. GA-25 - 701

It is certified that an inspection team headed by Lachin Singh Health Inspector
 (Name of Officers with designation) from A/o C.S. Roper
 (Name of Department/ Office) inspected the HOLY CHILD SMART SCHOOL PATTI
Nangal, Roper
 (Name & Address of the school) on 25/4/25 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitary condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
 The above is valid for a period of One Year

Signature with Seal: [Signature]

Name

ਨਿੱਲ: ਸਿਹਤ ਮੁਕਾਮ
 ਚੰਡੀਗੜ੍ਹ ਵਿੱਚ ਸਿਹਤ ਮੁਕਾਮ, ਗੁਰੂਗੜ੍ਹ

Designation :

Assistant Engineer of
 the Govt. Public Health Department (PHED)/
 Authorised officer of the Local Body

Name & Address of the Office / Department

To
Holy child Smart
School, Patti, Nangal, Roper

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

ਮਿਤੀ-30-04-2025

ਸ.ਪ.ਹ.ਲ (ਰਿਪੋਰਟ)/ਪੇ/2025/75

ਸਟੇਟ ਪਬਲਿਕ ਹੈਲਥ ਲਬੋਰਟਰੀ ਪੰਜਾਬ, ਖਰੜ।
State Public Health Laboratory Punjab, Kharar

ਸੇਵਾ ਵਿਖੇ,

ਸਿਵਲ ਸਰਜਨ, ਰੂਪਨਗਰ

ਵਿਸ਼ਾ :- ਪਾਣੀ ਦੇ ਸੈਂਪਲਾਂ ਦੀ ਬੈਕਟੀਰੀਅਲ ਅਤੇ ਕੈਮੀਕਲ ਟੈਸਟਾਂ ਦੇ ਆਧਾਰ ਤੇ ਵਿਸ਼ਲੇਸ਼ਣ ਰਿਪੋਰਟ।

ਆਪ ਵੱਲੋਂ ਮਿਤੀ 25-04-2025 ਨੂੰ ਭੇਜੇ ਗਏ ਪਾਣੀ ਦੇ ਸੈਂਪਲਾਂ ਦੀ ਵਿਸ਼ਲੇਸ਼ਣ ਰਿਪੋਰਟ ਇਸ ਲਬੋਰਟਰੀ ਵਿੱਚ ਕੀਤੇ ਗਏ ਟੈਸਟਾਂ (with respect to BIS guidelines ISO 10500: Drinking water specifications: 2012) ਦੇ ਆਧਾਰ ਤੇ ਹੇਠ ਅਨੁਸਾਰ ਹੈ।

ਲੜੀ ਨੰ	ਠੇਕਾ ਨੰ	ਸੈਂਪਲਾਂ ਦਾ ਵੇਰਵਾ Civil surgeon, Ropar	Urban/ Rural	TDS, pH, Chloride Fluoride, Calcium , Total Hardness, Residual free chlorine	ਪੀਣ ਯੋਗ/ ਅਯੋਗ	ਬੈਕਟੀਰੀਅਲ ਕੋਨਟੈਮੀਨੇਸ਼ਨ Coliform Bacteria ਪੀਣ ਯੋਗ/ ਅਯੋਗ
1	599	Govt. Institue Of nursing Ropar (tap water+RO)	Urban	Normal	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0
2	600	Govt. Institue Of nursing Ropar(mess) (tap water+RO)	Urban	Normal	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0
3	601	Punjab Internatinal public school, Pipal Majra ropar (tap water+RO)	Urban	Normal	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0
4	602	Hloy Child Smart School, Patti ropar (tap water+RO) Nangal.	Urban	Normal	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0
5	603	Akal Academy Kmalpur Ropar (tap water+RO)	Urban	Normal	ਪੀਣ ਯੋਗ	Coliform Bacteria MPN 0

BIS guidelienes Drinking water specifications - (IS 10500:1991/2003/2012)	REQUIREMENT (Acceptable Limit)	Permissible Limit in Absence of Alternate Source
TDS	500	2000
PH	6.5-8.5	No relaxation
Calcium	75	200
Chloride	250	1000
Fluoride	1.0	1.5
Total hardness	200	600
Free residual chlorine	0.2	1.0
Total Coliform Bacteria/100 ml	The Requirement is Coliform Bacteria Should not be Detectable in 100ml Sample.	

2. ਇਹ ਲਬੋਰਟਰੀ ਰਿਪੋਰਟ ਨਾਲ ਨਾ ਫੇਰੇ ਸੈਂਪਲ ਦੀ ਆਈ ਗਲਤ ਰਿਪੋਰਟ ਲਈ ਜ਼ਿੰਮੇਵਾਰ ਰਹੀ ਹੈ।

30/04/25
ਬੈਕਟੀਰੀਅਲਿਸਟ

ਇਥੋ: ਸਟੇਟ ਪਬਲਿਕ ਹੈਲਥ ਲਬੋਰਟਰੀ ਪੰਜਾਬ ਖਰੜ
ਰੋਮਿਥ (ਬੈਕਟੀਰੀਅਲ ਸੈਕਸ਼ਨ) ਰੋਮਿਥ (ਕੈਮੀਕਲ ਸੈਕਸ਼ਨ)